



**BUREAU
VERITAS**

**Bureau Veritas
Consumer Products Services
Germany GmbH**

Businesspark A96
86842 Türkheim
Germany
+ 49 (0) 40 740 41 – 0
cps-tuerkheim@de.bureauveritas.com

Certification body of BV CPS GmbH
Accredited according to EN 45011 -
ISO / IEC Guide 65

Certificate of compliance

Applicant: Steca Elektronik GmbH
Mammostraße 1
8770 Memmingen
Germany

Product: Grid-tied photovoltaic inverter

Model: StecaGrid 3600
StecaGrid 3600x

Use in accordance with regulations:

Automatic disconnection device with single-phase mains surveillance in accordance with IEC 61727:2004 and IEC62116:2008 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverters.

Applied rules and standards:

IEC 61727:2004

Photovoltaic (PV) systems – Characteristics of the utility interface

IEC 62116:2008

Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters

IEEE 1547:2003, IEEE 1547.1:2005 (harmonics, d.c.-injection, voltage and frequency disconnection, reconnection)

IEEE Standard Conformance Test Procedures for Equipment Interconnecting Distributed Resources with Electric Power Systems

AS 4777.3:2005 (grid protection requirements)

Grid connection of energy systems via inverters – inverter requirements and grid protection requirements

The following deviations for Thailand were applied:

Electricity Grid System Connection Requirements B.E. 2551 of Provincial Electricity Authority (PEA 2013) with attachment for Proclamation No. 6.2 for plants till 500kW:

*under voltage limit (level 1): 198,0V
under voltage limit (level 2): 170,0V
over voltage limit (level 1): 242,0V
overvoltage limit (level 2): 264,0V
lower frequency limit: 48,0Hz
upper frequency limit: 51,0Hz
loss of main detection limit: 2s*

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

Report number: 10TH0241-IEC61727
Certificate number: U14-0279
Date of issue: 2014-05-12

Certification body

Dieter Zitzmann



Deutsche
Akkreditierungsstelle
D-ZE-12024-01-01



QUALITY



HEALTH



SAFETY



ENVIRONMENT



SOCIAL
ACCOUNTABILITY